

July 1, 2021

Ref.: 269508

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. 029-21 (the "Tender") – Modifications and Clarifications #1

This notice ("**Notice**") from Energy Infrastructures Ltd. and/or Oil Products Pipeline Ltd. (the "**Company**") includes certain clarifications and updates regarding the Tender. Any term herein which is defined in the Tender Documents (as defined in the Tender) has the meaning ascribed to such term therein, unless and to the extent otherwise defined herein.

Modifications to the Tender

After consideration of circumstances including feedback received from some bidders, ***the Company has approved the following modifications to the Tender.*** Please note that these modifications include the full details regarding the new Bill of Quantities and updated Submission Deadline.

	<u>Issue</u>	<u>Modification</u>
1	Submission Deadline	The Submission Deadline for this Tender is extended to July 21, 2021.

Clarifications

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "**Questions**"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

	<u>Question</u>	<u>Answer</u>
1	Is it possible to offer alternative brands of plug valves products other than those indicated in the tender document? (OECD products complying with tender's technical requirements).	It is possible to offer alternative brands if the manufacturer complies with tender technical requirements
2	Where is it possible to find the datasheets of the Plug Valves to be supplied – we didn't find any reference to this information in the tender documents.	We did not reference data sheets in tender documents. We expect you to select manufacturer, they are required to submit data sheet and you are to confirm



		compliance with tender technical requirements
3	Under Chap 6 "General Features", it is specified Port Minimum opening 70%. Please consider that industry standard for this valve is around 50% , I can tell you that both Franklin and Cameron make these valves with 50% max opening. To make an actual 70% it's technically possible but it would make our price much higher and delivery longer.	The request is denied

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,

Talmor

Talmor Sela

Procurement and Engagements Department

