

#### Finance Division - Procurement & Engagements Department

March 29, 2020 Ref.: 238391

To: All Tender Participants

Dear Sir / Madam,

### Re: Public Tender No. 007-20 (the "Tender") – Clarifications and Updates #2

This notice includes certain clarifications and updates regarding the Tender. Any term herein which is defined in the Tender Documents has the meaning ascribed to such term therein, unless and to the extent otherwise defined herein.

# Modifications to the Tender

After consideration of circumstances including feedback received from some bidders, the Company has approved the following modifications to the Tender.

1. Extension of submission deadline. As previously publicized, the Company has decided to extend the submission deadline to Tuesday, April, 21st 2020 (the "Extended Deadline").

## **Clarifications**

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Questions"). Next to each Question is the Company's answer, which shall be considered by the Company to as authoritative.

	Question	<u>Answer</u>
1	Design standard according to API 609, face to face dimension	ASME B16.10 acceptable
	according to ASME B 16.10 or Api 6d (FTF:	
	406 mm'), 216 mm	
2	Leakage standard: API 6D – zero leakage. ISO 5208 Rate B	Not acceptable
3	Body Seat: Stellite weld overlay. Incoloy 825 HCr	Acceptable
4	Seat seal: RPTFE (min) None (our proposed valve does not have a seat seal within its construction)	Have been noted















#### Finance Division - Procurement & Engagements Department

5	Stem seal: shell meet liquid & pressure conditions Graphite	Have been noted
6	Shaft: ASTM A182 F6A (min) 17-4PH	Acceptable
7	Regarding Fire Test on valve acc. to API 607. Please confirm with the PEI that compliance with Fire Safe Design acc. to API 607 is enough. Fire Safe Certificate for Butterfly Valves is not common.	Acceptable

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,

Talmor Talmor Sela

Procurement and Engagements Department















