

To: All Tender Participants

Dear Sir / Madam,

**Re: Public Tender No. PD23000241 (the "Tender") –
 Notice Regarding Submission Deadline and Clarifications**

The Company has received requests for clarifications regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Question"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

| <u>Answer</u> | <u>Question</u> | | |
|--|---|---------------|---|
| המשאבה מותקנת OUTDOOR | האם המשאבה תותקן INDOOR או OUTDOOR? | Specification | 1 |
| יש להעביר עם ההצעה את המערכת המוצעת ע"י היצרן לאישור | גוון הציפוי האפוקסי צריך להיות מוגדר בעת ההזמנה ולא לפני השילוח | | 2 |
| לוחות הפיקוד יהיו בתקן NEMA4X | האם לוחות הפיקוד יהיו בתקן NEMA4 או בתקן NEMA4X? | | 3 |
| מצ"ב מפרט טכני מעודכן. ראו התייחסות נוספת בנוגע לספיקת המשאבה | | | 4 |

In addition, The Company has decided to extend the Submission Deadline to May 10, 2023 (the "Extended Deadline").

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Talmor Sela

Procurement and Engagements Department

