

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. PD22000951 (the "Tender") – Clarifications

The Company has received requests for clarifications regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Question"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

| | | <u>Question</u> | <u>Answer</u> |
|---|---------------|--|--|
| 1 | Paragraph 4.1 | The pump specification does not show the required rated pressure of the pump at 200 GPM rated flow. | The rated pressure required is 15 bar (162 m head) |
| 2 | Paragraph 4.3 | Please clarify the requirements and details of the flow metering device | There is not specific requirement. The pump is required to come with an accessory for measuring flow in accordance with the manufacturer recommendation. |
| 3 | Paragraph 2.4 | API-676 is not applicable to these pumps. They are designed and tested to NFPA Standards and UL/FM approved. Please advise | The pump shall meet the requirements of NFPA standards and UL/FM approved and do not need to conform to API 676 standards. Paragraph 2.4 is deleted. |
| 4 | | There is no sufficient information about the process specification, And duty point in order to select the suitable pump | Capacity 200 gpm, 162 m head |

In addition, The Company has decided to extend the Submission Deadline to August 3, 2022 (the "Extended Deadline").

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,

Talmor

Talmor Sela

Procurement and Engagements Department

