

November 9, 2023

Ref.: 305460

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. PD23001368 (the "Tender") – Clarifications

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "**Questions**"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

		<u>Question</u>	<u>Answer</u>
1	Lead time	Please change the requested delivery date in section 2.3 from 15 weeks to 30 or 72 weeks	Accepted 30 weeks
2.	Prepayment	We kindly ask to add 20% down payment with the order.	Accepted against bank guarantee.
3.	Annex E "Agreement for the Supply of Goods"	In item 3.5.2 of the document you mention supply of valves. Is this relevant to the project?	Supply of the goods in this tender.
6	Annex E "Agreement for the Supply of Goods"	Item 9.3 what is the entrance fee of Haifa port? Is this a onetime payment or do you have to pay each time you come inside the port with a truck of commissioning team. Where can we see the rates?	Not relevant
7.	Annex E "Agreement for the Supply of Goods"	A new section will be added: "3.8 - It is hereby agreed that the liability of the supplier wherever such liability may attach anywhere where compensation and/or indemnification for damages that will be placed upon the supplier due to this agreement and/or due to various Order of Services or due to shall not apply with respect to any vicarious or consequential damage fees including financial damage and/or for any act or omission by the company and/or anyone acting on its behalf, and it is also explicitly agreed that the maximum rate of compensation and/or indemnification will not exceed a the value of consideration as defined in your Order of Services, per order. The company hereby	Not accepted



		warrants and represents that it holds The Supplier harmless and waives any claim, suit or demand with respect to any sum exceeding the maximal limitation of liability as stated herein.”	
7	Technical specification	<p>As per tender technical specification, paragraph 4.1.7 The VSD shall have a “normal duty” rating of 100% continuous current with a short-time duty rating of 150% overload for one minute.</p> <p>This requirement refers usually required for to Heavy duty application with constant torque load. Based on our experience in this case heavy duty drive is not necessary furthermore when you have big challenge with the room dimensions.</p>	No change
8	Technical specification - Appendix A	<p>As per tender technical specification, Appendix A- 3.3 KV VSD DATA SHEET FOR KAMAD HAIFA, line 3.3 Motor rated current [A] - no data provided. On another hand, line 5.5 states Nominal Continues Current for Normal duty: 300A.</p> <p>As per requirements in line 5.31 Room space (WxLxH) [mm. max] 2000 X 2900 X 3400mm. The dimensions requirements can be fulfilled only with 260A nominal output current VSD for normal duty with overload capability of 110% for 60s that is standard for pumps applications</p>	No change
9	Technical specification -	<p>As per tender technical specification, Appendix B- 3.3 KV VSD DATA SHEET FOR KAMAD HADERA, line 3.3 Motor rated current [A] - no data provided. On another hand, line 5.5 states Nominal Continues Current for Normal duty: 300A.</p> <p>As per requirements in line 5.31 Room space (WxLxH) [mm. max] 1500 X 4500 X 2800mm. The requirements can be fulfilled By VSD with 260A nominal output current for normal duty with overload capability of 110% for 60s that is standard for pumps applications. Our 260A drive <u>standard</u> meet the height requirement with 2cm extra room on top.</p>	No change



6	Invitation	We kindly ask for site visit in order to see existing electric room and place where VSD would be installed	Not Possible

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

