

May 13, 2024
 Ref.: 312553

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. PD24000597 (the "Tender") – Clarification

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Questions"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

		<u>Question</u>	<u>Answer</u>
1	Technical	UL/FM don't have certification protocols for gate valves with gear operators. We require to offer gate valves only with handwheel (without gear box), UL/FM approved	approved
1	Technical	We require to offer gate valves with flanges drilling according to ANSI/ASME #125 or #150. ASME / ANSI doesn't have a #175 standard	OK (IT THE SAME DRILLING
1	Technical	In the technical specifications it's required that all the flanges should be flat face (f.f), but in the bill of quantities it's required that the 2" valves will be with raised face (r.f). Please clarify	flat face (f.f)
1	Technical	<p align="center">OPERATION במפרט שלכם בסעיף הנקרא</p> <p>Valve shall be hand operated and gear רשום בו: box</p>	<p>No need gear operated</p> <p>An update Technical specification.</p>

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

