

April 3, 2024
Ref.: 311428

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. PD24000566 (the "Tender") – Clarifications

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Questions"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

| | | <u>Question</u> | <u>Answer</u> |
|---|--------------------|---|--------------------------------|
| 1 | Bill Of Quantities | Pipes 12"/16"/20"- should be std or sch40 wall thickness? | Accepted STD instead of Sch.40 |

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

