



Q'ty	UNIT	NOMINAL SIZE	DESCRIPTION	REVISION	DATE	BY	APPR.
25	unit	4"	Flange ASTM B 16.5 A105 6 inch W.N.R.F # 150 SCH.STD				
24	unit	6"	Flange ASTM B 16.5 A105 6 inch W.N.R.F # 150 SCH.STD				
23	unit	1/2"	SPRAY NOZZLE, " FLOODJET" K-B-40				
22	unit	1"x1/2"	REDUCER COUPLING SCR'D API 3000#				
21	unit	1"	HALF COUPLING, SCR'D. 3000#				
20	m	1"	Pipe seamless B.E. sch-40 A106 GALV				
19	unit	6"	U bolt C.S.				
18	unit	4"	Stud bolt 5/8" * 3.3/4" B7+2nuts 2H galv				
17	unit	6"	Stud bolt 3/4" * 4.1/4" B7+2nuts 2H galv				
16	unit	4"	Gasket klingerit 4 Inch c4430 2mm #150				
14	unit	6"	Gasket klingerit 6 Inch c4430 1.5mm #150				
12	unit	4"	Flange ASTM B16.5 A105 S.O.r.f #150				
11	unit	6"	Flange ASTM B16.5 A105 S.O.r.f #150				
9	unit	6"x4"	CONCENTRIC REDUCER ASME B16.5 A105 WE.				
8	unit	6"	Equal tee cs A234 we, std				
7	unit	4"	Elbow 45° BW LR A234 c.s. std.				
6	unit	6"	Elbow 45° BW LR A234 c.s. std.				
5	unit	6"	Elbow 90° BW LR A234 c.s. std.				
4	m	4"	Pipe ASTM B36.10 A106 GrB seamless B.E. sch-40				
2	m	6"	Pipe ASTM B36.10 A106 GrB seamless B.E. sch-40				

הערות:
1. על המבולן לבדוק את כל המידות בשטח לפני התחלת העבודה.
* הספקה של קבלן

NO.	DESCRIPTION	DATE	BY	APPR.
P1	1.05.2021	L.P.		

REFERENCE DWG. REVISIONS

תחילת נספ ואנליזה בנייה
מסוף אלרואי
טבעות קירור
מיכל 4

DWG. No. 10-2658-005-P0
SCALE: A1
REV. DATE: 5.05.2021
REV. PO

NO.	DESCRIPTION	DATE	BY	APPR.
P1	1.05.2021	L.P.		



תחילת נספ ואנליזה בנייה
מסוף אלרואי
טבעות קירור
מיכל 4

DWG. No. 10-2658-005-P0
SCALE: A1
REV. DATE: 5.05.2021
REV. PO

PEN CONFIG.: TOP-ENG FILE: xx