



הערות:  
1. על הקבלן לבדוק את כל המידות בטשטש לפני התחלת העבודה.  
\* אספקה של קבלן

No.	Q'ty	UNIT	NOMINAL SIZE	DESCRIPTION	REVISIONS
25	14046	unit	4"	Flange ASTM B 16.5 A105 6 inch W.N.R.F # 150 SCH.STD	2
24	14065	unit	6"	Flange ASTM B 16.5 A105 6 inch W.N.R.F # 150 SCH.STD	11
23	21842	unit	1/2"	SPRAY NOZZLE, " FLOODJET" K-B-40	148
22	15302	unit	1"x1/2"	REDUCER COUPLING SCR'D API 3000#	148
21	15270	unit	1"	HALF COUPLING, SCR'D. 3000#	148
20	21584	m	1"	Pipe seamless B.E. sch-40 A106 GALV	110
19	*	unit	6"	U bolt C.S.	29
18	16709	unit	4"	Stud bolt 5/8" * 3.3/4" B7+2nuts 2H galv	16
17	16711	unit	6"	Stud bolt 3/4" * 4.1/4" B7+2nuts 2H galv	208
16					
15	14386	unit	4"	Gasket klingerit 4 Inch c4430 2mm #150	2
14	14366	unit	6"	Gasket klingerit 6 Inch c4430 1.5mm #150	26
13					
12	14037	unit	4"	Flange ASTM B16.5 A105 S.O.r.f #150	2
11	14057	unit	6"	Flange ASTM B16.5 A105 S.O.r.f #150	41
10					
9	15625	unit	6"x4"	CONCENTRIC REDUCER ASME B16.5 A105 WE.	2
8	14763	unit	6"	Equal tee cs A234 we, std	3
7					
6	21010	unit	4"	Elbow 45° BW LR A234 c.s. std.	2
5	21013	unit	6"	Elbow 45° BW LR A234 c.s. std.	3
4	21033	unit	6"	Elbow 90° BW LR A234 c.s. std.	2
3					
2	17968	m	4"	Pipe ASTM B36.10 A106 GrB seamless B.E. sch-40	0.3
1	17974	m	6"	Pipe ASTM B36.10 A106 GrB seamless B.E. sch-40	220
PART VOCAB					

JOB No. 3426		DES. L.P.		DWN. L.P.		CHKD. D.G.		APPR.		INITIAL DATE	
DWG. No.		DESCRIPTION		DATE		BY		APPR.		SCALE	
REFERENCE DWG.		REVISIONS		DATE		BY		APPR.		SCALE	
DWG. No. 10-2658-007-P0		DESCRIPTION		DATE		BY		APPR.		SCALE	

משרד הנדסה ואדריכלות  
מסוף אלרואי  
טבעות קירור  
מיכל 5

SCALE: A1  
REV. DATE: 5.04.2021  
REV. P0

DWG. No. 10-2658-007-P0  
PEN CONFIG: TOP-ENG FILE: xx